

CERTIFICATE OF COMPLIANCE

Mueller A454 - A459 Super Centurion Fire Hydrants

WE HEREBY CERTIFY that MUELLER CO. Super Centurion 250 Fire Hydrants are manufactured and tested at the Mueller ISO 9001 registered facility in Albertville, Alabama, USA. These 5-1/4" main valve hydrants are certified to ANSI/NSF 61 & 372, meet the requirements of AWWA C502 and are certified to the standards listed in the chart below. Production testing meets or exceeds the requirements of these standards.

APPROVALS / PRODUCTION TESTING						
Model No.	Description	AWWA (psi)	UL 246 (psi) *	FM 1150 (psi)	Hydro Shell (psi)	Hydro Seat Test (psi)
A454	3-Hose	250	250	250	500	500
A455	4-Hose			250		
A458	1-Pumper/3-Hose			250		
A459	2-Pumper/2-Hose			N/A		

** FM only approves open left hydrants and hydrants with 1 pumper. FM requires hose gate valves on all hydrants with 3 or more hose nozzles.*

Mueller certifies that hydrant shoes, upper & lower barrels, bonnet and caps are manufactured in the Mueller foundry in Albertville per Mueller QA procedures; each heat is tested and certified to be within the specification shown in the chart under a controlled program and in accordance with ASTM A126 Class B Gray Iron or ASTM A536 Ductile Iron as applicable.

All major castings (shoe, barrels, bonnet and caps) are primer coated with epoxy inside and out. Above ground exterior will be top coated with polyurethane enamel.

Sincerely,



Alan Channell
 Product Manager
 Mueller Company, Water Products Division
 956 Industrial Blvd., Albertville, AL 35950
 Website: www.muellercompany.com



A454



A455



A458



A459

January 2017