



ITEM NO	PART NUMBER	QTY	DESCRIPTION	MATERIAL
1	547743	1	36" INSULATION PAD (SOLD SEPERATELY)	ETHAFOAM 220 WHITE OR POLYLAM 1.7 DENSITY WHITE
2	548555	2	STAINLESS STEEL SUPPORT BRACKET	304L STAINLESS STEEL
3	780113	1	18" DIA CAST IRON LID W/ RECESSED TR (SOLD SEPERATELY)	CAST IRON ASTM A125 CLASS B AND CAST BRONZE ASTM B584/B62 ALLOY C84400/C83600
4	790043	4	2" HEX NUT	ASTM B16 ALLOY C36000
5	790244	1	36" x 36" SHELL	POLYETHELENE
6	790438	1	36" EXTENSION RING W/ 18" OPENING (SOLD SEPERATELY)	CAST IRON ASTM A48 CLASS 25A AND 0.375" A36 CARBON STEEL
7	106B2423--2-38N	1	2"X18" COPPER METER SETTER	LEAD FREE BRASS
8	550BN0750V01	2	2" BULKHEAD NIPPLE	ASTM B43 SEAMLESS RED BRASS C23000 O61 TEMPER



OPTION CODE: 000703
 *107B2422--2---N INSTALLED

INTERPRET THIS DRAWING IN ACCORDANCE WITH ASME Y14.5 2018		NAME: AOS	DATE: May-31-24	THIRD ANGLE PROJECTION	
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES. MACHINING TOLERANCES:		D.E. APPR.		TITLE: 2" VAULT SINGLE 36" DIA X 36" DEEP LEAD FREE BRASS	
X ±.1	XX ±.015	M.E. APPR.			
XXX ±.005		Q.A. APPR.			
ANGULAR CORNER BREAK FINISH ±1° .015/.025 125 μin. RA		DO NOT SCALE DRAWING			SIZE: C
MATERIAL:		STK NUMBER:		REF.NO.	DWG. NUMBER: 550VS3636FBB000644N
TITLE TO AND OWNERSHIP OF THIS ENGINEERING DATA REMAINS IN Mueller Co. ABSENT ON THE PART OF THE RECIPIENT TO THESE CONDITIONS IS PRESUMED.		SCALE: 0.220		WT:	REV: A
		SHEET 1 OF 1			

REVISIONS					
REV	ECR	DESCRIPTION	DRAWN BY	DATE	APPROVED
A		DRAWING CREATED	AOS	5/31/24	