

CERTIFICATE OF COMPLIANCE Mueller A441/A442 Modern Centurion Fire Hydrants

WE HEREBY CERTIFY that MUELLER CO. Modern Centurion 250 Fire Hydrants are manufactured and tested at the Mueller ISO 9001 registered facility in Albertville, Alabama, USA. Mueller certifies these hydrants and meet the requirements of AWWA C502 and are certified to ANSI/NSF 61 & 372. Production testing is performed in accordance with these standards and meets to the following specifications.

| Approvals/Production Testing | | | | |
|------------------------------|-----------|---------------|----------------------|--------------------------|
| Size | Model No. | AWWA (psi) | Hydro Shell (psi) | Hydro Seat Test (psi) |
| 5-1/4" | A441/A442 | 250 | 500 | 500 |

Mueller certifies that hydrant shoes, upper & lower barrels, weather and hose caps are manufactured per Mueller QA procedures; each heat is tested and certified to be within the specification shown in the chart under a controlled program and in accordance with ASTM A126 Class B Gray Iron or ASTM A536 Ductile Iron as applicable.

All major castings (shoe, barrels, bonnet and caps) are primer coated with epoxy inside and out. Above ground exterior will be top coated with polyurethane enamel.

Respectfully,

Alan Channell Product Manager

Mueller Company, Water Products Division 956 Industrial Blvd., Albertville, AL 35950 Website: www.muellercompany.com

January 2017